



State Water Resources Control Board

Division of Drinking Water

June 28, 2017

System No. 1502524

Razmig Minassian, Director
Camp AREV
P.O. Box 11145
Glendale, CA 91226

**CITATION NO. 03_19_17C_028
TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL VIOLATION
FOR SEPTEMBER & NOVEMBER 2016 – CAMP AREV WATER SYSTEM**

Dear Mr. Minassian,

The State Water Resources Control Board (hereinafter State Board), Division of Drinking Water has issued Citation No. 03_19_17C_028, for failure to comply with the provisions of the California Health & Safety Code and Title 22, California Code of Regulations. Specifically, the Camp AREV Water System (hereinafter "Water System") failed the total coliform maximum contaminant level (MCL) for the months of September and November 2016.

The California Safe Drinking Water Act, Section 116577, provides for the State Board to be reimbursed by the public water system for costs incurred for preparing and issuing an enforcement action to that system. Therefore, the Water System has been billed for the preparation and issuance of this citation. The State Board's current billing rate for enforcement activities is \$161 per hour. The hourly rate is subject to review and change upon approval. You will receive a bill for these costs following the end of the State's fiscal year, from our Fee Billing Unit in Sacramento.

Any person who is aggrieved by a citation, order or decision issued by the Deputy Director of the Division of Drinking Water under Article 8 (commencing with Health and Safety Code, Section 116625) or Article 9 (commencing with Health and Safety Code, Section 116650), of the Safe Drinking Water Act (Chapter 4, Part 12, Division 104, of the Health and Safety Code) may file a petition with the State Water Board for reconsideration of the citation, order or decision. Appendix 1 to the enclosed Citation contains the relevant statutory provisions for filing a petition for reconsideration (Health and Safety Code, Section 116701).


Petitions must be received by the State Board within 30 days of the issuance of the citation, order or decision by the Deputy Director. The date of issuance is the date when the Division of Drinking Water mails a copy of the citation, order or decision. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day. Petitions must be received by 5:00 p.m.

Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml

If you have any questions regarding this matter, please contact our office at (661) 335-7315 or via email at dwpdist19@waterboards.ca.gov.

Sincerely,



Jaswinder S. Dhaliwal, P.E.
Senior Sanitary Engineer
DRINKING WATER FIELD OPERATIONS BRANCH

Enclosures: Citation #03_19_17C_028

Certified Mail No. 7015 0640 0001 6185 1018

cc: Kern County Dept. of Public Health, Environmental Health Division (w/out enclosure)
Scott Moore, Contract Sampler, Seaco Technologies, Inc. (via email)

STATE OF CALIFORNIA
STATE WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

Name of Public Water System: Camp AREV Water System

Water System No: 1502524

Attention: Razmig Minassian, Director
Camp AREV
P.O. Box 11145
Glendale, CA 91226

Issued: June 28, 2017

CITATION FOR NONCOMPLIANCE

**TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL VIOLATION
CALIFORNIA CODE OF REGULATIONS, TITLE 22, SECTION 64426.1
SEPTEMBER & NOVEMBER 2016**

The California Health and Safety Code (hereinafter "CHSC"), Section 116650 authorizes the State Water Resources Control Board (hereinafter "State Board") to issue a citation to a public water system when the State Board determines that the public water system has violated or is violating the California Safe Drinking Water Act (hereinafter "California SDWA"), (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit, or order issued or adopted thereunder.

1 The State Board, acting by and through its Division of Drinking Water
2 (hereinafter "Division") and the Deputy Director for the Division, hereby
3 issues this citation pursuant to Section 116650 of the CHSC to the Camp
4 AREV Water System (hereinafter "Water System") for violation of CHSC,
5 Section 116555(a)(1) and California Code of Regulations (hereinafter
6 "CCR"), Title 22, Section 64426.1.

7
8 A copy of the applicable statutes and regulations are included in **Appendix**
9 **1**, which is attached hereto and incorporated by reference.

10
11 **STATEMENT OF FACTS**

12 The Water System is classified as a transient non-community water system
13 with a population of 300, via five service connections. The Division received
14 laboratory results for one (1) routine bacteriological sample collected on
15 September 14, 2016 from the distribution system, showed the presence of
16 total coliform bacteria. Two (2) of the three (3) repeat samples collected on
17 September 16, 2016, from the distribution system also tested positive for
18 total coliform bacteria. A bacteriological sample, collected on September
19 16, 2016, from Well 01, for Ground Water Rule (GWR) compliance and total
20 coliform rule compliance (fourth repeat sample), also tested positive for total
21 coliform bacteria. On September 27, 2016, the Water System provided
22 emergency disinfection and flushing of Well 01, 5,000-gallon storage tank,
23 and distribution system. Afterwards, the Water System collected a total of
24 seven (7) bacteriological samples from Well 01, 5,000-gallon storage tank
25 and distribution system on the same day; all seven (7) samples tested
26 negative for total coliform bacteria.

27

1 Due to the total coliform treatment technique trigger in September 2016, the
2 Water System was required to have a Level 1 Assessment completed within
3 30 days of the total coliform treatment technique trigger. On behalf of the
4 Water System, Scott Moore from Seaco Technologies, Inc. (contract
5 sampler and a certified distribution operator), conducted a Level 1
6 Assessment on October 13, 2016. According to the Level 1 Assessment,
7 the total coliform positive samples in September 2016, may be due to
8 infrequent use of the sampling sites. The distribution system was
9 subsequently disinfected and flushed.

10
11 On October 18, 2016, the Water System collected five (5) routine
12 bacteriological samples; one (1) of these samples tested positive for total
13 coliform bacteria. All three (3) repeat samples, collected on October 21,
14 2016, tested negative for total coliform bacteria. A bacteriological sample,
15 collected on October 21, 2016, from Well 01, for Ground Water Rule
16 compliance and total coliform rule compliance (fourth repeat sample), also
17 tested negative for total coliform bacteria.

18
19 Four (4) of the five (5) routine samples, collected on November 2, 2016,
20 tested positive for total coliform bacteria. Due to a second total coliform
21 treatment technique trigger within a period of 12 months, the Water System
22 was required to have a Level 1 Assessment completed within 30 days of the
23 total coliform MCL violation in November 2016. Aayush Khurana and Osiel
24 Jaime from the State Board inspected the Water System on November 17,
25 2016, to complete a Level 2 Assessment. Findings of the Level 2
26 Assessment are summarized in a letter dated November 23, 2016
27 (**Appendix 2**). The Water System was required to address the items within
28 60 days of the letter. As of writing of this citation, the State Board has not

received a written response to the Level 2 Assessment letter. As such, it is unknown if the deficiencies identified in the Level 2 Assessment have been corrected or not.

After providing emergency disinfection and flushing of the distribution system, the Water System collected five (5) routine bacteriological samples on December 13, 2016, and all five samples tested negative for total coliform bacteria. One (1) routine sample collected on March 20, 2017, from the distribution system, tested negative for total coliform bacteria. None of the total coliform positive samples, collected between September and November 2016, showed the presence of fecal coliform OR *Escherichia coli* (*E. coli*) bacteria. A summary of all bacteriological samples collected from January 2016 to March 2017, is provided as **Appendix 3**.

The Water System submitted public notification and proof of public notification to the State Board, for the total coliform MCL violations in September and November 2016. These documents are available on file.

DETERMINATION

CCR, Title 22, Section 64426.1, Total Coliform Maximum Contaminant Level (MCL) states that a public water system which collects fewer than 40 bacteriological samples per month is in violation of the total coliform MCL if more than one sample collected during any month is total coliform-positive.

The Water System took fewer than 40 bacteriological samples during September 2016. One (1) routine sample and two (2) repeat samples collected in September tested positive for total coliform bacteria. Four (4) routine samples collected in November 2016 also tested positive for total

coliform bacteria. Therefore, the State Board has determined that the Water System violated CCR, Title 22, Section 64426.1 during September and November 2016. The Water System has not addressed all deficiencies identified in the Level 2 Assessment dated November 23, 2016.

DIRECTIVES

The Water System is hereby directed to take the following actions:

1. Comply with CCR, Title 22, Section 64426.1, in all future monitoring periods.
2. By **July 14, 2017**, submit a written response to the State Board, explaining the actions taken to address the deficiencies identified in the Level 2 Assessment dated November 23, 2016 (**Appendix 2**).

All submittals required by this Citation shall be electronically submitted to the Division at the following address. The subject line for all electronic submittals corresponding to this citation shall include the following information: Water System name and number, citation number and title of the document being submitted.

Jaswinder S. Dhaliwal, P.E.
Senior Sanitary Engineer
DWPSDIST19@waterboards.ca.gov

The State Board reserves the right to make such modifications to this Citation as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.

1 Nothing in this Citation relieves the Water System of its obligation to meet
2 the requirements of the California SDWA (CHSC, Division 104, Part 12,
3 Chapter 4, commencing with Section 116270), or any regulation, standard,
4 permit or order issued or adopted thereunder.
5

6 **PARTIES BOUND**

7 This Citation shall apply to and be binding upon the Water System, its
8 owners, shareholders, officers, directors, agents, employees, contractors,
9 successors, and assignees.
10

11 **SEVERABILITY**

12 The directives of this Citation are severable, and the Water System shall
13 comply with each and every provision thereof notwithstanding the
14 effectiveness of any provision.
15

16 **FURTHER ENFORCEMENT ACTION**

17 The California SDWA authorizes the State Board to: issue a citation or order
18 with assessment of administrative penalties to a public water system for
19 violation or continued violation of the requirements of the California SDWA
20 or any regulation, permit, standard, citation, or order issued or adopted
21 thereunder including, but not limited to, failure to correct a violation identified
22 in a citation or compliance order. The California SDWA also authorizes the
23 State Board to take action to suspend or revoke a permit that has been
24 issued to a public water system if the public water system has violated
25 applicable law or regulations or has failed to comply with an order of the
26 State Board, and to petition the superior court to take various enforcement
27 measures against a public water system that has failed to comply with an

order of the State Board. The State Board does not waive any further enforcement action by issuance of this Citation.



Jaswinder S. Dhaliwal, P.E.

Senior Sanitary Engineer

DRINKING WATER FIELD OPERATIONS BRANCH

June 28, 2017

Date

Appendices (3):

1. Applicable Statutes and Regulations
2. Level 2 Assessment Letter dated November 23, 2016
3. Report Showing a Summary of Bacteriological Results
(January 2016 – March 2017)

Certified Mail No. 7015 0640 0001 6185 1018

Cc: Kern County Dept. of Public Health, Env. Health Division (w/out appendices)

Scott Moore, Seaco Technologies, Contract Sampler (via email)

APPENDIX 1. APPLICABLE STATUTES AND REGULATIONS FOR CITATION NO. 03_19_17C_028

NOTE: The following language is provided for the convenience of the recipient, and cannot be relied upon as the State of California's representation of the law. The published codes are the only official representation of the law. Regulations related to drinking water are in Titles 22 and 17 of the California Code of Regulations. Statutes related to drinking water are in the Health & Safety Code, the Water Code, and other codes.

California Health and Safety Code (CHSC):

Section 116271 states in relevant part:

- (a) The State Water Resources Control Board succeeds to and is vested with all of the authority, duties, powers, purposes, functions, responsibilities, and jurisdiction of the State Department of Public Health, its predecessors, and its director for purposes of all of the following:
- (1) The Environmental Laboratory Accreditation Act (Article 3 (commencing with Section 100825) of Chapter 4 of Part 1 of Division 101).
 - (2) Article 3 (commencing with Section 106875) of Chapter 4 of Part 1.
 - (3) Article 1 (commencing with Section 115825) of Chapter 5 of Part 10.
 - (4) This chapter and the Safe Drinking Water State Revolving Fund Law of 1997 (Chapter 4.5 (commencing with Section 116760)).
 - (5) Article 2 (commencing with Section 116800), Article 3 (commencing with Section 116825), and Article 4 (commencing with Section 116875) of Chapter 5.
 - (6) Chapter 7 (commencing with Section 116975).
 - (7) The Safe Drinking Water, Water Quality and Supply, Flood Control, River and Coastal Protection Bond Act of 2006 (Division 43 (commencing with Section 75001) of the Public Resources Code).
 - (8) The Water Recycling Law (Chapter 7 (commencing with Section 13500) of Division 7 of the Water Code).
 - (9) Chapter 7.3 (commencing with Section 13560) of Division 7 of the Water Code.
 - (10) The California Safe Drinking Water Bond Law of 1976 (Chapter 10.5 (commencing with Section 13850) of Division 7 of the Water Code).
 - (11) Wholesale Regional Water System Security and Reliability Act (Division 20.5 (commencing with Section 73500) of the Water Code).
 - (12) Water Security, Clean Drinking Water, Coastal and Beach Protection Act of 2002 (Division 26.5 (commencing with Section 79500) of the Water Code).
- (b) The State Water Resources Control Board shall maintain a drinking water program and carry out the duties, responsibilities, and functions described in this section. Statutory reference to "department," "state department," or "director" regarding a function transferred to the State Water Resources Control Board shall refer to the State Water Resources Control Board. This section does not impair the authority of a local health officer to enforce this chapter or a county's election not to enforce this chapter, as provided in Section 116500...
- (k)
- (1) The State Water Resources Control Board shall appoint a deputy director who reports to the executive director to oversee the issuance and enforcement of public water system permits and other duties as appropriate. The deputy director shall have public health expertise.
 - (2) The deputy director is delegated the State Water Resources Control Board's authority to provide notice, approve notice content, approve emergency notification plans, and take other action pursuant to Article 5 (commencing with Section 116450), to issue, renew, reissue, revise, amend, or deny any public water system permits pursuant to Article 7 (commencing with Section 116525), to suspend or revoke any public water system permit pursuant to Article 8 (commencing with Section 116625), and to issue citations, assess penalties, or issue orders pursuant to Article 9 (commencing with Section 116650). Decisions and actions of the deputy director taken pursuant to Article 5 (commencing with Section 116450) or Article 7 (commencing with Section 116525) are deemed decisions and actions taken, but are not subject to reconsideration, by the State Water Resources Control Board. Decisions and actions of the deputy director taken pursuant to Article 8 (commencing with Section 116625) and Article 9 (commencing with Section 116650) are deemed decisions and actions taken by the State Water Resources Control Board, but any aggrieved person may petition the State Water Resources Control Board for reconsideration of the decision or action. This subdivision is not a limitation on the State Water Resources Control Board's authority to delegate any other powers and duties.

Section 116555 states in relevant part:

- (a) Any person who owns a public water system shall ensure that the system does all of the following:
- (1) Complies with primary and secondary drinking water standards.
 - (2) Will not be subject to backflow under normal operating conditions.
 - (3) Provides a reliable and adequate supply of pure, wholesome, healthful, and potable water.

Section 116650 states in relevant part:

- (a) If the state board determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the state board may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.

- (b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.
- (c) A citation may specify a date for elimination or correction of the condition constituting the violation.
- (d) A citation may include the assessment of a penalty as specified in subdivision (e).
- (e) The state board may assess a penalty in an amount not to exceed one thousand dollars (\$1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation and shall be in addition to any liability or penalty imposed under any other law.

Section 116655 of the CHSC, states in relevant part:

"(a) Whenever the State Board determines that any person has violated or is violating this chapter, or any permit, regulation, or standard issued or adopted pursuant to this chapter, the director may issue an order doing any of the following:

- (1) Directing compliance forthwith.
- (2) Directing compliance in accordance with a time schedule set by the State Board.
- (3) Directing that appropriate preventive action be taken in the case of a threatened violation.
- (b) An order issued pursuant to this section may include, but shall not be limited to, any or all of the following requirements:
 - (1) That the existing plant, works, or system be repaired, altered, or added to.
 - (2) That purification or treatment works be installed.
 - (3) That the source of the water supply be changed.
 - (4) That no additional service connection be made to the system.
 - (5) That the water supply, the plant, or the system be monitored.
 - (6) That a report on the condition and operation of the plant, works, system, or water supply be submitted to the State Board."

Section 116701 of the CHSC, states in relevant part:

- (a) Within 30 days of issuance of an order or decision issued by the deputy director under Article 8 (commencing with Section 116625) or Article 9 (commencing with Section 116650), an aggrieved person may petition the state board for reconsideration. Where the order or decision of the deputy director is issued after a hearing under Chapter 5 (commencing with Section 11500) of Part 1 of Division 3 of Title 2 of the Government Code, this section shall apply instead of Section 11521 of the Government Code.
- (b) The petition shall include the name and address of the petitioner, a copy of the order or decision for which the petitioner seeks reconsideration, identification of the reason the petitioner alleges the issuance of the order was inappropriate or improper, the specific action the petitioner requests, and other information as the state board may prescribe. The petition shall be accompanied by a statement of points and authorities of the legal issues raised by the petition.
- (c) The evidence before the state board shall consist of the record before the deputy director and any other relevant evidence that, in the judgment of the state board, should be considered to implement the policies of this chapter. The state board may, in its discretion, hold a hearing for receipt of additional evidence.
- (d) The state board may refuse to reconsider the order or decision if the petition fails to raise substantial issues that are appropriate for review, may deny the petition upon a determination that the issuance of the order or decision was appropriate and proper, may set aside or modify the order or decision, or take other appropriate action. The state board's action pursuant to this subdivision shall constitute the state board's completion of its reconsideration.
- (e) The state board, upon notice and hearing, if a hearing is held, may stay in whole or in part the effect of the order or decision of the deputy director.
- (f) If an order of the deputy director is subject to reconsideration under this section, the filing of a petition for reconsideration is an administrative remedy that must be exhausted before filing a petition for writ of mandate under Section 116625 or 116700."

California Code of Regulations, Title 22 (CCR):

Section 64421 (General Requirements) states:

- (a) Each water supplier shall:
 - (1) Develop a routine sample siting plan as required in section 64422;
 - (2) Collect routine, repeat and replacement samples as required in Sections 64423, 64424, and 64425;
 - (3) Have all samples analyzed by laboratories approved to perform those analyses by the State Board and report results as required in section 64423.1;
 - (4) Notify the State Board when there is an increase in coliform bacteria in bacteriological samples as required in section 64426; and
 - (5) Comply with the Maximum Contaminant Level as required in section 64426.1.
- (b) Water suppliers shall perform additional bacteriological monitoring as follows:
 - (1) After construction or repair of wells;
 - (2) After main installation or repair;
 - (3) After construction, repair, or maintenance of storage facilities; and
 - (4) After any system pressure loss to less than five psi. Samples collected shall represent the water quality in the affected portions of the system.

Section 64422 (Routine Sample Siting Plan) states:

- (a) By September 1, 1992, each water supplier shall develop and submit to the State Board a siting plan for the routine collection of samples for total coliform analysis, subject to the following:

- (1) The sample sites chosen shall be representative of water throughout the distribution system including all pressure zones, and areas supplied by each water source and distribution reservoir.
- (2) The water supplier may rotate sampling among the sample sites if the total number of sites needed to comply with (a)(1) above exceeds the number of samples required according to Table 64423-A. The rotation plan shall be described in the sample siting plan.
- (b) If personnel other than certified operators will be performing field tests and/or collecting samples, the sample siting plan shall include a declaration that such personnel have been trained, pursuant to §64415 (b).
- (c) The supplier shall submit an updated plan to the State Board at least once every ten years and at any time the plan no longer ensures representative monitoring of the system.

Section 64423 (Routine Sampling) states:

- (a) Each water supplier shall collect routine bacteriological water samples as follows:
- (1) The minimum number of samples for community water systems shall be based on the known population served or the total number of service connections, whichever results in the greater number of samples, as shown in Table 64423-A. A community water system using groundwater which serves 25-1000 persons may request from the State Board a reduction in monitoring frequency. The minimum reduced frequency shall not be less than one sample per quarter.
 - (2) The minimum number of samples for nontransient-noncommunity water systems shall be based on the known population served as shown in Table 64423-A during those months when the system is operating. A nontransient-noncommunity water system using groundwater which serves 25-1000 persons may request from the State Board a reduction in monitoring frequency if it has not violated the requirements in this article during the past twelve months. The minimum reduced frequency shall not be less than one sample per quarter.
 - (3) The minimum number of samples for transient-noncommunity water systems using groundwater and serving 1000 or fewer persons a month shall be one in each calendar quarter during which the system provides water to the public.
 - (4) The minimum number of samples for transient-noncommunity water systems using groundwater and serving more than 1000 persons during any month shall be based on the known population served as shown in Table 64423-A, except that the water supplier may request from the State Board a reduction in monitoring for any month the system serves 1000 persons or fewer. The minimum reduced frequency shall not be less than one sample in each calendar quarter during which the system provides water to the public.
 - (5) The minimum number of samples for transient-noncommunity water systems using approved surface water shall be based on the population served as shown in Table 64423-A. A system using groundwater under the direct influence of surface water shall begin monitoring at this frequency by the end of the sixth month after the State Board has designated the source to be approved surface water.
 - (6) A public water system shall collect samples at regular time intervals throughout the month, except that a system using groundwater which serves 4,900 persons or fewer may collect all required samples on a single day if they are taken from different sites.
- (b) In addition to the minimum sampling requirements, all water suppliers using approved surface water which do not practice treatment in compliance with Sections 64650 through 64666, shall collect a minimum of one sample before or at the first service connection each day during which the turbidity level of the water delivered to the system exceeds 1 NTU. The sample shall be collected within 24 hours of the exceedance and shall be analyzed for total coliforms. If the water supplier is unable to collect and/or analyze the sample within the 24-hour time period because of extenuating circumstances beyond its control, the supplier shall notify the State Board within the 24-hour time period and may request an extension. Sample results shall be included in determining compliance with the MCL for total coliforms in Section 64426.1.
- (c) If any routine, repeat, or replacement sample is total coliform-positive, then the water supplier shall collect repeat samples in accordance with Section 64424 and comply with the reporting requirements specified in Sections 64426 and 64426.1.

Table 64423-A
Minimum Number of Routine Total Coliform Samples

| Monthly Population Served | Service Connections | Minimum Number of Samples |
|---------------------------|---------------------|---------------------------|
| 25 to 1000 | 15 to 400 | 1 per month |
| 1,001 to 2,500 | 401 to 890 | 2 per month |
| 2,501 to 3,300 | 891 to 1,180 | 3 per month |
| 3,301 to 4,100 | 1,181 to 1,460 | 4 per month |
| 4,101 to 4,900 | 1,461 to 1,750 | 5 per month |
| 4,901 to 5,800 | 1,751 to 2,100 | 6 per month |
| 5,801 to 6,700 | 2,101 to 2,400 | 7 per month |
| 6,701 to 7,600 | 2,401 to 2,700 | 2 per week |
| 7,601 to 12,900 | 2,701 to 4,600 | 3 per week |
| 12,901 to 17,200 | 4,601 to 6,100 | 4 per week |
| 17,201 to 21,500 | 6,101 to 7,700 | 5 per week |
| 21,501 to 25,000 | 7,701 to 8,900 | 6 per week |
| 25,001 to 33,000 | 8,901 to 11,800 | 8 per week |
| 33,001 to 41,000 | 11,801 to 14,600 | 10 per week |
| 41,001 to 50,000 | 14,601 to 17,900 | 12 per week |
| 50,001 to 59,000 | 17,901 to 21,100 | 15 per week |
| 59,001 to 70,000 | 21,101 to 25,000 | 18 per week |
| 70,001 to 83,000 | 25,001 to 29,600 | 20 per week |
| 83,001 to 96,000 | 29,601 to 34,300 | 23 per week |

| | | |
|------------------------|------------------------|--------------|
| 96,001 to 130,000 | 34,301 to 46,400 | 25 per week |
| 130,001 to 220,000 | 46,401 to 78,600 | 30 per week |
| 220,001 to 320,000 | 78,601 to 114,300 | 38 per week |
| 320,001 to 450,000 | 114,301 to 160,700 | 50 per week |
| 450,001 to 600,000 | 160,701 to 214,300 | 55 per week |
| 600,001 to 780,000 | 214,301 to 278,600 | 60 per week |
| 780,001 to 970,000 | 278,601 to 346,400 | 70 per week |
| 970,001 to 1,230,000 | 346,401 to 439,300 | 75 per week |
| 1,230,001 to 1,520,000 | 439,301 to 542,900 | 85 per week |
| 1,520,001 to 1,850,000 | 542,901 to 660,700 | 90 per week |
| 1,850,001 to 2,270,000 | 660,701 to 810,700 | 98 per week |
| 2,270,001 to 3,020,000 | 810,701 to 1,078,600 | 105 per week |
| 3,020,001 to 3,960,000 | 1,078,601 to 1,414,300 | 110 per week |
| 3,960,001 or more | 1,414,301 or more | 120 per week |

Section 64423.1 (Sample Analysis and Reporting of Results) states:

(a) The water supplier shall designate (label) each sample as routine, repeat, replacement, or "other" pursuant to Section 64421(b), and have each sample analyzed for total coliforms. The supplier also shall require the laboratory to analyze the same sample for fecal coliforms or *Escherichia coli* (*E. coli*) whenever the presence of total coliforms is indicated. As a minimum, the analytical results shall be reported in terms of the presence or absence of total or fecal coliforms, or *E. coli* in the sample, whichever is appropriate.

(b) The water supplier shall require the laboratory to notify the supplier within 24 hours, whenever the presence of total coliforms, fecal coliforms or *E. coli* is demonstrated in a sample or a sample is invalidated due to interference problems, pursuant to Section 64425(b), and shall ensure that a contact person is available to receive these analytical results 24-hours a day. The water supplier shall also require the laboratory to immediately notify the State Board of any positive bacteriological results if the laboratory cannot make direct contact with the designated contact person within 24 hours.

(c) Analytical results of all required samples collected for a system in a calendar month shall be reported to the State Board not later than the tenth day of the following month, as follows:

(1) The water supplier shall submit a monthly summary of the bacteriological monitoring results to the State Board.

(2) For systems serving fewer than 10,000 service connections or 33,000 persons, the water supplier shall require the laboratory to submit copies of all required bacteriological monitoring results directly to the State Board.

(3) For systems serving more than 10,000 service connections, or 33,000 persons, the water supplier shall require the laboratory to submit copies of bacteriological monitoring results for all positive routine samples and all repeat samples directly to the State Board.

(d) Laboratory reports shall be retained by the water supplier for a period of at least five years and shall be made available to the State Board upon request.

Section 64424 (Repeat Sampling) states in relevant part:

(a) If a routine sample is total coliform-positive, the water supplier shall collect a repeat sample set as described in paragraph (1) within 24 hours of being notified of the positive result. The repeat samples shall all be collected within the same 24 hour time period. A single service connection system may request that the State Board allow the collection of the repeat sample set over a four-day period.

(1) For a water supplier that normally collects more than one routine sample a month, a repeat sample set shall be at least three samples for each total coliform-positive sample. For a water supplier that normally collects one or fewer samples per month, a repeat sample set shall be at least four samples for each total coliform-positive sample.

(2) If the water supplier is unable to collect the samples within the 24-hour time period specified in subsection (a) or deliver the samples to the laboratory within 24 hours after collection because of circumstances beyond its control, the water supplier shall notify the State Board within 24 hours. The State Board will then determine how much time the supplier will have to collect the repeat samples.

(b) When collecting the repeat sample set, the water supplier shall collect at least one repeat sample from the sampling tap where the original total coliform-positive sample was taken. Other repeat samples shall be collected within five service connections upstream or downstream of the original site. At least one sample shall be from upstream and one from downstream unless there is no upstream and/or downstream service connection.

(c) If one or more samples in the repeat sample set is total coliform-positive, the water supplier shall collect and have analyzed an additional set of repeat samples as specified in subsections (a) and (b). The supplier shall repeat this process until either no coliforms are detected in one complete repeat sample set or the supplier determines that the MCL for total coliforms specified in Section 64426.1 has been exceeded and notifies the State Board.

(d) If a public water system for which fewer than five routine samples/month are collected has one or more total coliform-positive samples, the water supplier shall collect at least five routine samples the following month. If the supplier stops supplying water during the month after the total coliform-positive(s), at least five samples shall be collected during the first month the system resumes operation. A water supplier may request the State Board waive the requirement to collect at least five routine samples the following month, but a waiver will not be granted solely on the basis that all repeat samples are total coliform-negative. To request a waiver, one of the following conditions shall be met:

(1) The State Board conducts a site visit before the end of the next month the system provides water to the public to determine whether additional monitoring and/or corrective action is necessary to protect public health.

(2) The State Board determines why the sample was total coliform-positive and establishes that the system has corrected the problem or will correct the problem before the end of the next month the system serves water to the public. If a waiver is granted, a system

shall collect at least one routine sample before the end of the next month it serves water to the public and use it to determine compliance with Section 64426.1.

Section 64425 (Sample Invalidation) states:

(a) A water supplier may request the Department to invalidate a sample for which a total coliform-positive result has been reported if the supplier demonstrates:

- (1) All repeat sample(s) collected at the same tap as the original total coliform-positive sample also are total coliform-positive and all repeat samples collected within five service connections of the original tap are not total coliform-positive; or
- (2) The laboratory did not follow the prescribed analytical methods pursuant to §64415(a), based on a review of laboratory documentation by the Department. The supplier shall submit to the Department a written request for invalidation along with the laboratory documentation, the supplier's sample collection records and any observations noted during sample collection and delivery. The water supplier shall require the laboratory to provide the supplier with documentation which shall include, but not be limited to:
 - (A) A letter from the director of the laboratory having generated the data, confirming the invalidation request by reason of laboratory accident or error;
 - (B) Complete sample identification, laboratory sample log number (if used), date and time of collection, date and time of receipt by the laboratory, date and time of analysis for the sample(s) in question;
 - (C) Complete description of the accident or error alleged to have invalidated the result(s);
 - (D) Copies of all analytical, operating, and quality assurance records pertaining to the incident in question; and
 - (E) Any observations noted by laboratory personnel when receiving and analyzing the sample(s) in question.

(b) Whenever any total coliform sample result indicative of the absence of total coliforms has been declared invalid by the laboratory due to interference problems as specified at 40 Code Federal Regulations, Section 141.2100(c)(2), the supplier shall collect a replacement sample from the same location as the original sample within 24 hours of being notified of the interference problem, and have it analyzed for the presence of total coliforms. The supplier shall continue to re-sample at the original site within 24 hours and have the samples analyzed until a valid result is obtained.

Section 64426 (Significant Rise in Bacterial Count) states in relevant part:

(a) Any of the following criteria shall indicate a possible significant rise in bacterial count:

- (1) A system collecting at least 40 samples per month has a total coliform-positive routine sample followed by two total coliform-positive repeat samples in the repeat sample set;
- (2) A system has a sample which is positive for fecal coliform or E. coli; or
- (3) A system fails the total coliform Maximum Contaminant Level (MCL) as defined in Section 64426.1.

(b) When the coliform levels specified in subsection (a) are reached or exceeded, the water supplier shall:

- (1) Contact the State Board by the end of the day on which the system is notified of the test result or the system determines that it has exceeded the MCL, unless the notification or determination occurs after the State Board office is closed, in which case the supplier shall notify the State Board within 24 hours; and
- (2) Submit to the State Board information on the current status of physical works and operating procedures which may have caused the elevated bacteriological findings, or any information on community illness suspected of being waterborne. This shall include, but not be limited to:
 - (A) Current operating procedures that are or could potentially be related to the increase in bacterial count;
 - (B) Any interruptions in the treatment process;
 - (C) System pressure loss to less than 5 psi;
 - (D) Vandalism and/or unauthorized access to facilities;
 - (E) Physical evidence indicating bacteriological contamination of facilities;
 - (F) Analytical results of any additional samples collected, including source samples;
 - (G) Community illness suspected of being waterborne; and
 - (H) Records of the investigation and any action taken.

Section 64426.1 (Total Coliform Maximum Contaminant Level (MCL)) states in relevant part:

(b) A public water system is in violation of the total coliform MCL when any of the following occurs:

- (1) For a public water system which collects at least 40 samples per month, more than 5.0 percent of the samples collected during any month are total coliform-positive; or
- (2) For a public water system which collects fewer than 40 samples per month, more than one sample collected during any month is total coliform-positive; or
- (3) Any repeat sample is fecal coliform-positive or E. coli-positive; or
- (4) Any repeat sample following a fecal coliform-positive or E. coli-positive routine sample is total coliform-positive.

(c) If a public water system is not in compliance with paragraphs (b)(1) through (4), during any month in which it supplies water to the public, the water supplier shall notify the State Board by the end of the business day on which this is determined, unless the determination occurs after the State Board office is closed, in which case the supplier shall notify the State Board within 24 hours of the determination. The water supplier shall also notify the consumers served by the water system. A Tier 2 Public Notice shall be given for violations of paragraph (b)(1) or (2), pursuant to section 64463.4. A Tier 1 Public Notice shall be given for violations of paragraph (b)(3) or (4), pursuant to section 64463.1.

Section 64463.1 (Tier 1 Public Notice) states in relevant part:

(a) A water system shall give public notice pursuant to this section and section 64465 if any of the following occurs:

- (1) Violation of the total coliform MCL when:

- (A) Fecal coliform or E. coli are present in the distribution system; or
 - (B) When any repeat sample tests positive for coliform and the water system fails to test for fecal coliforms or E. coli in the repeat sample;...
- (b) As soon as possible within 24 hours after learning of any of the violations in subsection (a) or being notified by the State Board that it has determined there is a potential for adverse effects on human health [pursuant to paragraph (a)(4), (5), or (6)], the water system shall:
- (1) Give public notice pursuant to this section;
 - (2) Initiate consultation with the State Board within the same timeframe; and
 - (3) Comply with any additional public notice requirements that are determined by the consultation to be necessary to protect public health.
- (c) A water system shall deliver the public notice in a manner designed to reach residential, transient, and nontransient users of the water system and shall use, as a minimum, one of the following forms:
- (1) Radio or television;
 - (2) Posting in conspicuous locations throughout the area served by the water system;
 - (3) Hand delivery to persons served by the water system; or
 - (4) Other method approved by the State Board, based on the method's ability to inform water system users.

Section 64463.4 (Tier 2 Public Notice) states:

- (a) A water system shall give public notice pursuant to this section if any of the following occurs:
- (1) Any violation of the MCL, MRDL, and treatment technique requirements, except:
 - (A) Where a Tier 1 public notice is required under section 64463.1; or
 - (B) Where the State Board determines that a Tier 1 public notice is required, based on potential health impacts and persistence of the violations;
 - (2) All violations of the monitoring and testing procedure requirements in sections 64421 through 64426.1, article 3 (Primary Standards – Bacteriological Quality), for which the State Board determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations;
 - (3) Other violations of the monitoring and testing procedure requirements in this chapter, and chapters 15.5, 17 and 17.5, for which the State Board determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations; or
 - (4) Failure to comply with the terms and conditions of any variance or exemption in place.
- (b) A water system shall give the notice as soon as possible within 30 days after it learns of a violation or occurrence specified in subsection (a), except that the water system may request an extension of up to 60 days for providing the notice. This extension would be subject to the State Board's written approval based on the violation or occurrence having been resolved and the State Board's determination that public health and welfare would in no way be adversely affected. In addition, the water system shall:
- (1) Maintain posted notices in place for as long as the violation or occurrence continues, but in no case less than seven days;
 - (2) Repeat the notice every three months as long as the violation or occurrence continues. Subject to the State Board's written approval based on its determination that public health would in no way be adversely affected, the water system may be allowed to notice less frequently but in no case less than once per year. No allowance for reduced frequency of notice shall be given in the case of a total coliform MCL violation or violation of a Chapter 17 treatment technique requirement; and
 - (3) For turbidity violations pursuant to sections 64652.5(c)(2) and 64653(c), (d) and (f), as applicable, a water system shall consult with the State Board as soon as possible within 24 hours after the water system learns of the violation to determine whether a Tier 1 public notice is required. If consultation does not take place within 24 hours, the water system shall give Tier 1 public notice within 48 hours after learning of the violation.
- (c) A water system shall deliver the notice, in a manner designed to reach persons served, within the required time period as follows:
- (1) Unless otherwise directed by the State Board in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, community water systems shall give public notice by:
 - (A) Mail or direct delivery to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system; and
 - (B) Use of one or more of the following methods to reach persons not likely to be reached by a mailing or direct delivery (renters, university students, nursing home patients, prison inmates, etc.):
 - 1. Publication in a local newspaper;
 - 2. Posting in conspicuous public places served by the water system, or on the Internet; or
 - 3. Delivery to community organizations.
 - (2) Unless otherwise directed by the State Board in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, noncommunity water systems shall give the public notice by:
 - (A) Posting in conspicuous locations throughout the area served by the water system; and
 - (B) Using one or more of the following methods to reach persons not likely to be reached by a public posting:
 - 1. Publication in a local newspaper or newsletter distributed to customers;
 - 2. E-mail message to employees or students;
 - 3. Posting on the Internet or intranet; or
 - 4. Direct delivery to each customer.

Section 64465 (Public Notice Content and Format) states in relevant part:

- (a) Each public notice given pursuant to this article, except Tier 3 public notices for variances and exemptions pursuant to subsection (b), shall contain the following:

- (1) A description of the violation or occurrence, including the contaminant(s) of concern, and (as applicable) the contaminant level(s);
 - (2) The date(s) of the violation or occurrence;
 - (3) Any potential adverse health effects from the violation or occurrence, including the appropriate standard health effects language from appendices 64465-A through G;
 - (4) The population at risk, including subpopulations particularly vulnerable if exposed to the contaminant in drinking water;
 - (5) Whether alternative water supplies should be used;
 - (6) What actions consumers should take, including when they should seek medical help, if known;
 - (7) What the water system is doing to correct the violation or occurrence;
 - (8) When the water system expects to return to compliance or resolve the occurrence;
 - (9) The name, business address, and phone number of the water system owner, operator, or designee of the water system as a source of additional information concerning the public notice;
 - (10) A statement to encourage the public notice recipient to distribute the public notice to other persons served, using the following standard language: —Please share this information with all the other people who drink this water, especially those who may not have received this public notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail; and
 - (11) For a water system with a monitoring and testing procedure violation, this language shall be included: "We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During [compliance period dates], we ['did not monitor or test' or 'did not complete all monitoring or testing'] for [contaminant(s)], and therefore, cannot be sure of the quality of your drinking water during that time." ...
- (c) A public water system providing notice pursuant to this article shall comply with the following multilingual-related requirements:
- (2) For a Tier 2 or Tier 3 public notice:
 - (A) The notice shall contain information in Spanish regarding the importance of the notice, or contain a telephone number or address where Spanish-speaking residents may contact the public water system to obtain a translated copy of the notice or assistance in Spanish; and
 - (B) When a non-English speaking group other than Spanish-speaking exceeds 1,000 residents or 10 percent of the residents served by the public water system, the notice shall include:
 1. Information in the appropriate language(s) regarding the importance of the notice; or
 2. A telephone number or address where such residents may contact the public water system to obtain a translated copy of the notice or assistance in the appropriate language; and
 - (3) For a public water system subject to the Dymally-Alatorre Bilingual Services Act, Chapter 17.5, Division 7, of the Government Code (commencing with section 7290), meeting the requirements of this Article may not ensure compliance with the Dymally-Alatorre Bilingual Services Act.
- (d) Each public notice given pursuant to this article shall:
- (1) Be displayed such that it catches people's attention when printed or posted and be formatted in such a way that the message in the public notice can be understood at the eighth-grade level;
 - (2) Not contain technical language beyond an eighth-grade level or print smaller than 12 point; and
 - (3) Not contain language that minimizes or contradicts the information being given in the public notice.

Appendix 64465-A. Health Effects Language - Microbiological Contaminants.

| Contaminant | Health Effects Language |
|------------------------|---|
| Total Coliform | Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. |
| Fecal coliform/E. coli | Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems. |
| Turbidity | Turbidity has no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. |

Section 64469 (Reporting Requirements) states in relevant part:

- (d) Within 10 days of giving initial or repeat public notice pursuant to Article 18 of this Chapter, except for notice given under section 64463.7(d), each water system shall submit a certification to the State Board that it has done so, along with a representative copy of each type of public notice given.

Section 64481 (Content of the Consumer Confidence Report) states in relevant part:

- (g) For the year covered by the report, the Consumer Confidence Report shall note any violations of paragraphs (1) through (7) and give related information, including any potential adverse health effects, and the steps the system has taken to correct the violation.
- (1) Monitoring and reporting of compliance data

APPENDIX 2

Level 2 Assessment Letter dated November 23, 2016



State Water Resources Control Board
Division of Drinking Water

November 23, 2016

Razmig Minassian, Director
Camp AREV
P.O. Box 11145
Glendale, CA 91226

SUBJECT: LEVEL 2 ASSESSMENT OF THE CAMP AREV WATER SYSTEM (NO. 1502524)

Dear Mr. Minassian:

On November 17, 2016, Aayush Khurana, Water Resource Control Engineer with the State Water Resources Control Board (hereinafter State Board), Division of Drinking Water, inspected the Camp AREV Water System (hereinafter Water System) to complete a Level 2 Assessment. Osiel Jaime, Sanitary Engineer with the State Board was also present during the site visit and assisted in preparation of the Level 2 Assessment. The Level 2 Assessment was required under the federal revised Total Coliform Rule, following the *Coliform Treatment Technique Trigger* in September and November 2016. A copy of the Level 2 Assessment Form is provided in **Enclosure A**. Some pictures taken during the site visit are provided under **Enclosure B**. Below, you will find our major recommendations.


1. Drain/empty, clean, and disinfect the 5,000-gallon storage tank and continue to do so at least once every five years. Some sediments were noted at the tank bottom (see Picture #1 under **Enclosure B**).
2. Provide screens on the vent on top of the storage tank and seal the areas around the level indicator. These spaces are currently unprotected from possible entry of rain, bugs, and small critters (see Picture #2 in **Enclosure B**).
3. Modify the inlet of the storage tank from bottom to the top of the tank to prevent stagnation of water in the storage tank.
4. Install a sample tap on Well 01's discharge line, upstream of the storage tank, to allow collecting a sample directly from the well.
5. Within 60 days, have a Cross-Connection Control Specialist complete a cross-connection survey of the Water System and submit a report of the findings to the State Board within 90 days. Since there is no information available about the connection of the two fire tanks to the domestic water supply system, a cross-connection survey would help identify any actual or potential cross-connections and methods to protect the domestic water supply system.

November 23, 2016

The cause of bacteriological contamination in September and November 2016 may be attributed to the deficiencies identified at the storage tank. Please implement the recommendations stated above to lower the chance of future bacteriological contamination. **The items identified above should be addressed within 60 days and written notification to the State Board should be submitted after taking corrective actions.**

If you have any questions concerning the issues discussed in this letter, please contact Aayush Khurana at (661) 335-7346.

Sincerely,



Jaswinder S. Dhaliwal, P.E.

Senior Sanitary Engineer

STATE WATER RESOURCES CONTROL BOARD

DIVISION OF DRINKING WATER

ENCLOSURES

Enclosure A: Level 2 Assessment Form


Enclosure B: Inspection Pictures

cc: Kern County Dep. of Public Health, Environmental Health Services Division (w/o enclosures)
Scott Moore, Seaco Technologies, Inc. (via e-mail)

Enclosure A

Level 2 Assessment Form

REVISED TOTAL COLIFORM RULE (RTCR) – LEVEL 2 ASSESSMENT



This form is intended to assist Division of Drinking Water (DDW) or Local Primacy Agency (LPA) Staff in completing the investigation required by the federal revised Total Coliform Rule (rTCR) [effective April 1, 2016]. If the answer has a large box around it, it is an issue and needs to be described by LPA or DDW in the next column. Please include the question number in the description. The PWS must address each issue described in the Corrective Action column. To avoid a violation, the water system must submit to DDW/LPA a completed assessment report no later than 30 days after the trigger date.

| | | | | | |
|---|--|--|--|------------------------------|--|
| PWS ID#: 15025244 | | PWS Name: [Camp Aven] | | Circle one: CWS / NTNC (TNC) | |
| Operator in Responsible Charge (print name): SCOTT MOORE | | Phone: 661-323-5115 | | | |
| Assessment trigger date: 11/02/2016 | | Date Assessment Completed: 11/17/2016 | | | |
| SEASONAL: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> | | Reason for Assessment: Second F Coli violation in two months | | | |
| Person who collected TC positive samples: STEVE | | Contact info for person who collected samples: GC LABS | | | |
| Name of Certified Lab conducting sample analysis: GC LABS | | | | | |

| Assessment Elements | | Y | N | N/A | Issue Description | Corrective Action Taken or Planned to be Taken and Date |
|-------------------------------|---|-------------------------------------|-------------------------------------|--------------------------|---|---|
| 1. Review of the sample sites | | Y | N | N/A | Indicate Element number being described | Indicate Element number being described |
| 1.1 | Was the sample taken at the routine coliform site? List the name(s) of the positive sample site(s). | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Cottage front/back; lodge front/back | |
| 1.2 | Was the tap area unsanitary at the time of sampling? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 1.3 | Was this sample taken from an outside faucet? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Cottage + lodge (outside), mgns column (inside) | |
| 1.4 | Was the sample taken from a swivel tap? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | nose | |
| 1.5 | Did the tap have a point of use treatment device on it? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 1.6 | Does the building where the sample was taken have a point of entry device? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 1.7 | Has this location undergone any plumbing replacements or repairs? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 1.8 | Are there any possible cross connections around the sample site (including yard hydrants and stock tanks)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 1.9 | Is this location near a storage tank or dead end? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Tank near sample site | |
| 1.10 | Have there been any analytical results or any additional samples collected, including source samples, which were positive (not for compliance)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 1.11 | Prior to this incident, when was the most recent satisfactory coliform samples taken? | | | | | |
| 1.12 | Any other sample site issues not previously mentioned? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |

REVISED TOTAL COLIFORM RULE (RTC) - LEVEL 2 ASSESSMENT

| 2. Review of sample protocol | | Y | N | N/A | Indicate Element number being described | Indicate Element number being described |
|--------------------------------------|---|-------------------------------------|-------------------------------------|-------------------------------------|--|---|
| 2.1 | Was the positive sample(s) taken by the operator in responsible charge? Provide name of sampler. | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | by Steve (trained sampler) | |
| 2.2 | Is the sampler a regular, trained sampler? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 2.3 | Was a laboratory-provided TC sample bottle used? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 2.4 | Was the aerator removed? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 2.5 | Was the water tap flushed for at least 5 minutes? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 2.6 | Was the tap (disinfected or flamed)? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Disinfected | |
| 2.7 | Did the sample get too warm prior to being placed on ice? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 2.8 | Were there other sampler errors? Describe | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 2.9 | If it is a seasonal system, were there any problems during the most recent start-up procedure? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 2.10 | Any other sample protocol issues not previously mentioned (e.g. vandalism or unauthorized access)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3. Review of the distribution system | | Y | N | N/A | Indicate Element number being described | Indicate Element number being described |
| 3.1 | Have any mains or service lines recently been repaired, replaced or installed? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3.2 | Have fire hydrants or blow offs been recently flushed/used/sheared? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | leaving Sprinkler system fixed (last week) | |
| 3.3 | Have valves been recently exercised to direct flow? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3.4 | Any leaks or main breaks noted? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | none exist | |
| 3.5 | Are all of the backflow prevention devices operational and maintained? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 3.6 | Was there a total loss of pressure, low pressure (<20 psi) or changes in water pressure? If yes, when? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3.7 | Any areas of the distribution with low disinfectant levels (<0.2 mg/L)? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | no treatment | |
| 3.8 | Any recent pump station failures or repairs? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3.9 | Air relief valve leaking? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3.10 | Standing water or debris in (air relief) valve vault? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3.11 | Any recent power loss? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3.12 | Any unprotected cross connections (including yard hydrants and stock tanks)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3.13 | Has high turbidity been detected in the distribution system? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3.14 | Is there evidence of intentional contamination or vandalism? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 3.15 | Any other distribution issue not previously mentioned (e.g. other O&M activities that could have introduced coliforms)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |

REVISED TOTAL COLIFORM RULE (RTC) - LEVEL 2 ASSESSMENT

| 4. Review of storage tank(s) (Note the specific facility if any issues are found) | | Y | N | N/A | Indicate Element number being described. | Indicate Element number being described. |
|--|--|-------------------------------------|-------------------------------------|-------------------------------------|--|--|
| 4.1 | Is there a presence of animals or insects in the tank(s)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.2 | Are there breaches or holes of any sort into tank(s)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.3 | Is there any presence of animal droppings around openings, vents or overflows? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.4 | Is there sediment buildup and floating debris in tank(s)? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 4.5 | Have the tank(s) been cleaned within the last 5 years? If not, list when it was last cleaned. | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.6 | Are the vents and overflows protected against entry from animals, insects or other contaminants? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.7 | Are the screens damaged or not properly installed? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 4.8 | Does the reservoir have a common inlet/outlet? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.9 | Is the overflow pipe directly connected to a tank drain, sanitary sewer or storm drain? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 4.10 | Does the hatch have a solid, water proof, shoebox type lid that is properly sealed? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 4.11 | Was the hatch locked or secured? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.12 | Has the tank been accidentally drained? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.13 | Have there been high flows through the tank? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.14 | Was there high water age in the tank (infrequent water use)? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 4.15 | Was the sample taken when the tank was at the low level mark? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.16 | Failure or improper operation on tank telemetry/altitude valves/controls? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.17 | Any recent repairs on the tank(s)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.18 | Was there any power loss? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.19 | Is the site secured (e.g. fencing, locked gates, etc.)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.20 | Was the tank vandalized or subject to tampering? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.21 | Any other storage tank issues not previously mentioned above? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| Pressure Tanks (if applicable) | | Y | N | N/A | Indicate Element number being described. | Indicate Element number being described. |
| 4.22 | What is the volume of the pressure tank? Attach additional sheets if needed. | | 4 x 81 gallon | | | |
| 4.23 | What is the age of the pressure tank? Attach additional sheets if needed. | | Unknown | | | |
| 4.24 | Does the pressure tank use a bladder and/or air compressor? Attach additional sheets if needed. | | bladder | | | |
| 4.25 | Did the pressure tank(s) deviate from normal operating pressure? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 4.26 | Is the compressor pump running more than normal? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |

REVISED TOTAL COLIFORM RULE (RTCR) - LEVEL 2 ASSESSMENT

| | | | | | | | | | | | |
|------|---|-------------------------------------|-------------------------------------|-------------------------------------|--|--|--|--|--|--|--|
| 4.27 | Is the tank bladder water logged? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 4.28 | Is the tank damaged, rusty, leaking or have holes? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 4.29 | Was there any recent work performed on the tank? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 4.30 | Is the air relief vent (if there one) screened and facing down? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 4.31 | Can the inside of the pressure tank be visually inspected through an inspection port? If so, when was it last inspected? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5. | Review of treatment process (if applicable) | Y | N | N/A | | | | | | | Indicate Element number being described. |
| 5.1 | Has the treatment been bypassed altogether at any time or have individual processes been interrupted by power outages or other causes? If yes, provide details on when, which processes and for how long? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.2 | Have there been any new treatment processes added or new equipment installed? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.3 | Have there been any recent repairs of major unit processes or treatment equipment? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.4 | Have there been any changes in the operational procedures used for treating the water such as, changes in chemical dosages, flow changes, or changes in coagulant chemicals used? If yes, provide details of the change and when it occurred. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.5 | Has a coagulant been added at all times the plant has been filtering water? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.6 | Have there been changes in raw water quality? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.7 | Was the settled water turbidity increasing? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.8 | Was the finished water turbidity increasing? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.9 | Have filter clogging algae caused more frequent backwashing? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.10 | Have there been any failures in adding disinfectant for any length of time? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.11 | Was water delivered that did not meet CT requirements? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.12 | What is the entry point chlorine residual today? | | | | | | | | | | |
| 5.13 | Free/Total? | | | | | | | | | | mg/L |
| 5.13 | Has there been any vandalism or tampering at the plant? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | |
| 5.14 | Any other treatment plant issues not previously mentioned above? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | |
| 6. | Sources - Well(s) | Y | N | N/A | | | | | | | Indicate Element number being described. |
| 6.1 | (Note the specific facility if any issues are found) | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | |
| 6.2 | Is there a 50 foot annular seal? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | |
| 6.2 | Is the surface seal defective or damaged or not water tight? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | |

no treatment provided

no well log on file
submersive pump

REVISED TOTAL COLIFORM RULE (RTC) - LEVEL 2 ASSESSMENT

| | | | | | | |
|---|--|-------------------------------------|-------------------------------------|-------------------------------------|---------|------------------|
| 6.3 | Is there a casing vent? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 6.4 | Does the casing and/or air relief vent have a screen to prevent the entry of insects? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 6.5 | Does the vent and pump to waste terminate in an air gap of at least three pipe diameters above the ground? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 6.6 | How is the well used? (Circle if applicable) | | | | | no pump to waste |
| 6.7 | Are there any unprotected cross connections at the wellhead? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | Primary | Emergency |
| 6.8 | Are there any unprotected openings in the pump or pump assembly? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 6.9 | Is the pitless adapter damaged? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 6.10 | Are there any exposed holes or cracks near the wellhead? For example electric conduit | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 6.11 | Has there been any recent work performed on the pump? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 6.12 | Is the wellhead secured to prevent unauthorized access? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 6.13 | Have there been any sewer spills, source water spills or other disturbances near the well? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 6.14 | Is the wellhead at least 18-inches above grade? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| 6.15 | Is there evidence of standing water near the wellhead? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 6.16 | Is the well pit in standing water or evidence of flooding? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| 6.17 | Any other well issues not previously mentioned above? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | |
| Sources - Spring(s) (Note the specific facility if any issues are found) | | Y | N | N/A | | |
| 6.18 | Is there evidence of flooding or infiltration of surface water runoff around the spring? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.19 | Is the spring box improperly developed or poorly maintained? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.20 | Is the spring site secured (e.g. locks, fence, gate, etc). | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.21 | Are there dead animals near the spring? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.22 | Any other issues about springs not previously mentioned above? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| Sources - Surface Water | | Y | N | N/A | | |
| 6.23 | Have there been algae blooms? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.24 | Has the source water turned over? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.25 | Have there been any sewer spills, source water spills or other disturbances? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.26 | Any other source water issues not previously mentioned above? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |

REVISED TOTAL COLIFORM RULE (RTC) - LEVEL 2 ASSESSMENT

| Sources-purchased water | | | | | |
|------------------------------------|--|--------------------------|-------------------------------------|---|--|
| 6.27 | Water quality issues with supplier? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | Bottled water provided for divers | |
| 6.28 | Low disinfectant residual from supplier (typically ≤ 0.2 mg/L)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.29 | Any other purchased water issues not previously mentioned above? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| Applicable to all sources | | | | | |
| 6.30 | Has an unapproved source been used? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.31 | Has there been a change in sources? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.32 | Has there been recent rapid snowmelt, heavy rainfall or flooding? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.33 | Any evidence of animals near the source? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.34 | Have there been changes in available source water (e.g. significant drop in water table, reservoir capacity)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.35 | Is the source water sample for ground water systems E. coli positive? This may indicate that the positive sample is originating from the source and may be a continuous source of contamination. | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 6.36 | Any other source issues not previously mentioned above? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| 7. General Operations | | | | | |
| 7.1 | During or soon after bacteriological quality problems, did you receive any complaints of any customers' illness suspected of being waterborne? How many? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | Indicate Element number being described | |
| 7.2 | What were the symptoms of illness if you received complaints about customers being sick? | N/A | | | |
| 7.3 | Were there any extreme weather/natural events (e.g. heat, freezing, raining, windy, fires, earthquakes etc) | <input type="checkbox"/> | <input checked="" type="checkbox"/> | Indicate Element number being described | |
| 8. Significant Deficiencies | | | | | |
| 8.1 | Are there any unaddressed significant deficiencies? This may indicate that the problem is known and is in the process of being remedied. Include approved corrective action date and status of each corrective action. | <input type="checkbox"/> | <input checked="" type="checkbox"/> | Indicate Element number being described | |

1. Attach additional sheets if needed.

REVISED TOTAL COLIFORM RULE (RTCR) – LEVEL 2 ASSESSMENT

Additional Comments:

Recommended charging inlet to top of tank
and adding a sample tap before the tank. Regular cleaning +
flushing also

Name of SWRCB-Division of Drinking Water or LPA representative completing the form (PRINTED): ARYASH KHORANA

Signature: *Aryash*

Date: 11/17/2016

Water system responsible party (PRINTED): SCOTT MOORE

Signature: *Scott Moore*

Date: 11/17/2016

Reserved for Regulatory Agency (DDW / LPA) Review

| | Yes | NC | Comments |
|---|-------------------------------------|--------------------------|------------------|
| 1. Has assessment been successfully completed? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| 2. Likely reason for EC+ occurrence has been found. | <input type="checkbox"/> | <input type="checkbox"/> | NA only TC found |
| 3. System has corrected the problem. | <input type="checkbox"/> | <input type="checkbox"/> | |
| 4. Were all issues identified corrected? | <input type="checkbox"/> | <input type="checkbox"/> | 3 pending |
| 4. Corrective Action Approved? | <input type="checkbox"/> | <input type="checkbox"/> | |

Enclosure B


Inspection Pictures

1. Storage Tank Bottom



The water in the 5,000-gallon storage tank appears to be stagnated. There is a layer of floating particles on the top. The tank should be drained or emptied, cleaned, and disinfected.

2. Level Indicator of the Storage Tank



The areas around the level indicator of the storage tank are unsealed. The red circle shows the portion that must be sealed. The tank's vent must also be screened. There should be no possible entry points for rain or bugs and small animals.

3. Pressure Tanks



The four 81-gallon pressure tanks are relatively new. There were no leaks or other sanitary hazards around these tanks. These tanks have bladders in them. The integrity of the tank bladders must be checked every 5 years.

APPENDIX 3

Report Showing a Summary of Bacteriological Results (January 2016 – March 2017)

Camp Arev

1502524

Distribution System Freq: 1/Q

| Sample Date | Time | Location | T Coli | E Coli | F Coli | Type | CI2 | Violation | Comment |
|-------------|-------|------------------|--------|--------|--------|---------|-----|-----------|-----------------------------|
| 3/14/2016 | 10:28 | "Cottage, Front" | A | A | | Routine | 0 | | |
| 3/14/2016 | 10:31 | "Lodge, Rear" | A | A | | Routine | 0 | | |
| 3/14/2016 | 10:42 | "Cabin, Mgr. " | A | A | | Routine | 0 | | |
| 4/7/2016 | 11:12 | Rear Lodge | A | A | | Routine | 0 | | |
| 4/7/2016 | 11:16 | Front Lodge | A | A | | Routine | 0 | | |
| 4/7/2016 | 11:22 | Mgrs. Cabin | A | A | | Routine | 0 | | |
| 4/7/2016 | 11:28 | Cottage Front | A | A | | Routine | 0 | | |
| 4/7/2016 | 11:43 | Cottage Rear | A | A | | Routine | 0 | | |
| 6/15/2016 | 10:56 | Lodge Front | A | A | | Routine | 0 | | |
| 9/14/2016 | 9:56 | Cottage Front | P | A | | Routine | 0 | | |
| 9/16/2016 | 10:02 | Mgrs. Cabin | A | A | | Repeat | 0 | | |
| 9/16/2016 | 10:10 | Lodge Front | P | A | | Repeat | 0 | MCL | Cit. #03_19_17C_028 issued. |
| 9/16/2016 | 10:14 | Lodge Rear | P | A | | Repeat | 0 | | |
| 9/27/2016 | 11:00 | Kitchen | A | A | | Routine | 0 | | |
| 9/27/2016 | 11:40 | "Lodge, Front" | A | A | | Routine | 0 | | |
| 9/27/2016 | 11:43 | "Lodge, Rear" | A | A | | Routine | 0 | | |
| 9/27/2016 | 11:51 | "Cottage, Front" | A | A | | Routine | 0 | | |
| 9/27/2016 | 11:54 | "Cottage, Rear" | A | A | | Routine | 0 | | |
| 9/27/2016 | 12:02 | "Cabin, Mgrs" | A | A | | Routine | 0 | | |
| 9/27/2016 | 12:25 | Storage Tank | A | A | | Routine | 0 | | |
| 10/18/2016 | 13:23 | Mgrs. Cabin | P | A | | Routine | 0 | | |
| 10/18/2016 | 13:28 | "Cottage, Front" | A | A | | Routine | 0 | | |
| 10/18/2016 | 13:30 | "Cottage, Rear" | A | A | | Routine | 0 | | |
| 10/18/2016 | 13:36 | "Lodge, Front" | A | A | | Routine | 0 | | |
| 10/18/2016 | 13:39 | "Lodge, Rear" | A | A | | Routine | 0 | | |
| 10/21/2016 | 15:13 | Mgrs. Cabin | A | A | | Repeat | 0 | | |
| 10/21/2016 | 15:16 | "Lodge, Front" | A | A | | Repeat | 0 | | |
| 10/21/2016 | 15:19 | "Lodge, Rear" | A | A | | Repeat | 0 | | |
| 11/2/2016 | 11:00 | Lodge Front | 11 | A | | Routine | 0 | MCL | Cit. #03_19_17C_028 issued. |
| 11/2/2016 | 11:03 | Lodge Rear | 5.3 | A | | Routine | 0 | | MPN/100mL |
| 11/2/2016 | 11:10 | Mgrs Cabin | <1 | A | | Routine | 0 | | MPN/100mL |
| 11/2/2016 | 11:18 | Cottage Front | 11 | A | | Routine | 0 | | MPN/100mL |
| 11/2/2016 | 11:20 | Cottage Rear | 3.1 | A | | Routine | 0 | | MPN/100mL |
| 12/13/2016 | 11:28 | Mgrs. Cabin | A | A | | Routine | | | |
| 12/13/2016 | 11:32 | Cottage Front | A | A | | Routine | | | |

| <i>Sample Date</i> | <i>Time</i> | <i>Location</i> | <i>T Coli</i> | <i>E Coli</i> | <i>F Coli</i> | <i>Type</i> | <i>Cl2</i> | <i>Violation</i> | <i>Comment</i> |
|--------------------|-------------|-----------------|---------------|---------------|---------------|-------------|------------|------------------|----------------|
| 12/13/2016 | 11:34 | Cottage Rear | A | A | | Routine | | | |
| 12/13/2016 | 11:39 | Lodge Rear | A | A | | Routine | | | |
| 12/13/2016 | 11:40 | Lodge Front | A | A | | Routine | | | |
| 3/20/2017 | 9:42 | "Lodge, Rear" | A | A | | Routine | 0 | | |

Camp Arev

1502524

Source Monitoring Freq:

| <i>Sample Date</i> | <i>Time</i> | <i>Source</i> | <i>T Coli</i> | <i>E Coli</i> | <i>F Coli</i> | <i>Violation</i> | <i>Comment</i> |
|--------------------|-------------|----------------------------|---------------|---------------|---------------|------------------|-------------------|
| 3/14/2016 | 10:38 | Well #001 / Repeat / Quant | A | A | | | |
| 4/7/2016 | 11:05 | Well #001 / Routine | A | A | | | |
| 9/16/2016 | 9:57 | Well 001 / Repeat | P | A | | | GWR/Repeat Sample |
| 9/27/2016 | 12:19 | Well 001 / Routine | A | A | | | |
| 10/21/2016 | 15:09 | Well 001 / Repeat | A | A | | | GWR/Repeat Sample |
